

ELK-4/ELK-4F

GALAXY CAPACITIVE LEVEL ELECTRODE

GENERAL FEATURES

Ayvaz Compact System Galaxy ELK-4/ELK-4F work according conductivity measurement principle. ELK 4/ ELK 4F capable of displaying 4 levels in conductor liquids;

- 4 levels each with one contact point:
- High level alarm,
- Low level alarm,
- Pump start,
- Pump stop.

ELK 4/ELK 4F ensure the control of all functions inside the panel. No external control device required.

Conductivity of liquid is utilized for displaying the level of liquid. Minimum conductivity of liquid must be measured in order to ensure safe functioning of device. With this feature of fluids, two conditions can be detected.

- Electrode rod dipped / exposed,
- Switch point accessed / not accessed

Before the assembly, sizes of electrode rods must be adapted according to contact levels. (For example; maximum / minimum alarm or pump control

Application Areas:


- -Steam Boilers
- -Supply Tanks
- -Chemical Applications


	LENGTH(mm)		
ELK-4	500	1000	1500
ELK-4F	436	936	1436


	Connections	
ELK-4	Threaded 1" BSP (DIN ISO 228)	
ELK-4F	Flanged (DN 50 and above PN 40 DIN 2635)	

Technical Specifications				
Max. Working Temperature	238 °C			
Max. Working Pressure	32 bar			
Main Feeding	230 V + % 10, 50-60 Hz			
Body	Stainless Steel			
Flange	Forged Steel			
Case	Aluminum Injection			
Reading Electrode	Stainless Steel			

ELK-4/ELK-4F GALAXY CAPACITIVE LEVEL ELECTRODE








ELK-4 SPARE PARTS				
No	Item	Part	Material	Dims.
1	2	Bonner	Aluminum	
2	1	Panel Body	Aluminum	
3	1	Control Panel Circuit	Breadboard	
4	1	Panel Connection Bolt		
5	1	Nut		M12
6	1	Heat Insulation Rod Cover		
7	1	Heat Insulation Rod	AISI 304	
8	4	Electrode Switch Nut	transmission	
9	4	Washer		M4
10	4	Electrode Pipe Stabilizer	teflon	
11	4	Washer		
12	4	Electrode Press Spring	spring steel	
13	! !	Electrode Sealing Cover	teflon	
14	1	Electrode Body	AISI 316 Ti	BSP1"
15	1	Electrode Body Gasket	AISI 304	
16	1	Sleeve	Steel	BSP1"
17	4	Electrode Switch Teflon Cover Lock		
18		Electrode Switch Teflon Cover	teflon	
19	1	Centering Piece	teflon	
20	4	Electrode Switch Pipe	AISI 316 Ti	
21	1	Bolt	Silicon	
22	1	Nut		R 1/2"
23	1	Nut		R 3/8"
24	9	Washer		M4
25	9	Bolt		M4x10
26	8	Gasket		Ø4
27	8	Bolt		M4x16
28	3	Rivet		
29	2	Label		

ELK-4/ELK-4F GALAXY CAPACITIVE LEVEL ELECTRODE





	ELK-4F SPARE PARTS				
No	Part Name	Materials			
1	Silicon Cable				
2	Cable Socket -1				
3	Cablo Socket -2	1			
4	Thermal Insulation Pipe Cover				
5	Thermal Insulation Pipe	AISI 304			
6	Gasket	Transmission			
7	Washer				
8	Electrode Pipe Fixing Part	Teflon			
9	Washer				
10	Electrode Pressure Spring	Spring Teflon			
11	Electrode Sealing Cover	Teflon			
12	Electrode Body	AISI 316 Ti			
13	Electrode Body Gasket	AISI 304			
14	Electrode Connection Flange	C22.8			
15	Holder				
16	Insulation	Teflon			
17	Centering Part	Teflon			
18	Electrode	AISI 316 Ti			

Level

Drop

ELK-4/ELK-4F GALAXY CAPACITIVE LEVEL ELECTRODE

The control of the level in the boiler or tanks is carried out with the help of sensors operating on different principles.


Conductivity Rod:


Principle of operation: The sensor determines the level of water according to the electrical conductivity of the environment in which it is contacted.


The water level in the boiler:

It is not possible to read level of water during the production of steam by the classical water level indicator.

When the steam is produced, the water-level consists of steam-water mixture bubbles, and the precise water level can not be detected because the water level is in motion. The water level observed outside the boiler is read as lower than the actual water level in the boiler. The reason for this is that the water density at the water level indicator outside the boiler is higher.








Water level without steam production

Water level in steam production

It transmits the current, which is the contact with water.



It doesn't transmit the current, which is not the contact with water.

Factors affecting the difference between the actual water level and the water level read from the outside:

- 1- Boiler Steam Capacity
- 2 Height of boiler outer level indicator compared to boiler
- 3-Chemical properties of boiler water
- 4-Size of boiler body

The advantages:

- 1-Self-testing level caps remove the necessity of daily testing of the system.
- 2- These systems are safe because products do not consistof moving elements and they do not need maintenance.



HEAD OFFICE - FACTORY

Atatürk Sanayi Bölgesi Hadımköy Mahallesi Mustafa İnan Caddesi No: 44 Arnavutköy - İSTANBUL Tel: +90 212 771 01 45 (pbx) | Fax: +90 212 771 47 27 info@ayvaz.com | www.ayvaz.com